



STATEMENT SHOWING THE ACTION TAKEN REPORT BY THE HMWS&SB AGAINST THE "UN WHOLESOME"


SAMPLES REPORTED BY I.P.M DURING THE MONTH OF JANUARY-2014

SL. No.	I.P.M Lab Ref. No.	Location	O&M Div. No.	Section	Action taken Report by Concerned Manager (Engg.) Rectified / Work in progress	Resampling by QAT of HMWSSB					Satisfactory / Unsatisfactory
						RC	H2S	Date	Lab Ref. No.	Bacteriological Analysis	
1.	98	Tap inside at Mysaram Section	II	Maisaram	Rectified	2.0	--	02-02-2014	21551	Wholesome	Satisfactory
2.	114	PSP near 1-14-262/C (opp Ambedker Statue) Balamrai Sec-bad	Contonment Supply - Not Related to HMWS&SB Supply								
3.	147	Stored water at H.No: 19-3-543/81 at Alibagh Aliabad	I	Miralam	Rectified	0.2	--	03-02-2014	3766	Wholesome	Satisfactory
4.	196	House Tap at 42-587/1, at Mysamma nagar, Jagadgirigutta	XII	Adarsh nagar	Rectified	1.0	--	25-02-2014	22857	Wholesome	Satisfactory
5.	216	House Tap at D.No: 8-1-37/B at Viratnagar , ToliChowki	III	Tolichowki	Rectified	1.0	--	18-02-2014	22470	Wholesome	Satisfactory
6.	248	Tap inside at Mysaram section	II	Maisaram	Rectified	2.0	--	02-02-2014	21551	Wholesome	Satisfactory
7.	285	Outlet tap water near main gate at Bhagyanagar S/R KPHB	IX	Bhagyanagar	Rectified	0.5	--	17-02-2014	22360	Wholesome	Satisfactory
8.	287	House tap at LIGH KPHB No: 117/11 ,IV Th Phase Quarters	IX	KPHB	Rectified	0.5	--	22-02-2014	22681	Wholesome	Satisfactory

SL. No.	I.P.M Lab Ref. No.	Location	O&M Div. No.	Section	Action taken Report by Concerned Manager (Engg.) Rectified / Work in progress	Resampling by QAT of HMWSSB					Satisfactory / Unsatisfactory
						RC	H2S	Date	Lab Ref. No.	Bacteriological Analysis	
9.	301	Tanker Filling Point-Phase -1 KPHB Colony , KPHB Municipality	IX	KPHB	Rectified	0.5	--	25-02-2014	22825	Wholesome	Satisfactory
10.	319	House Tap at 22-1-144, Kali Kaber , Chaderghat	I	Moghalpura	Rectified	0.2	--	22-02-2014	3997 (MRG)	Wholesome	Satisfactory
11	340	House Tap pit at 1-9-67 Rajendranagar Municipality	XVI	Hyderguda	Rectified	1.5	--	19-02-2014	22492	Wholesome	Satisfactory


Technical Officer (QAT)
 Bacteriological Section
 Central Laboratory.


Dy. General Manager (QAT)
 Quality Assurance & Testing Wing,
 HMWS&SB, Hyderabad


General Manager (QAT) /c
 Quality Assurance & Testing Wing,
 HMWS&SB, Hyderabad

1. Copy submitted to the Managing Director, HMWS&SB for favour of information
2. Copy submitted to the Director (Technical), HMWS&SB for favour of information.
3. Copy submitted to the Chief Water Analyst, I.P. M, Narayanguda for favour of information