

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
75	10/01/14	124	Metro	PSP Outside at Gode-Ki-Kaber Section	2.0	Nil	Satisfactory
76	15/01/14	126	Metro	Outlet tap at Beerappagadda S/R, Uppal	1.0	Nil	Satisfactory
77	15/01/14	128	Metro	House tap at H.No: 1-20-9/26, Chilkanagar Slum	1.0	Nil	Satisfactory
78	15/01/14	130	Metro	House tap at H.No: 2-1-72/B Laxmareddynagar , Uppal	1.0	Nil	Satisfactory
79	15/01/14	132	Metro	PSP at Elugutta Section Reservoir , Uppal	1.0	Nil	Satisfactory
80	15/01/14	134	Metro	House tap at H.No: 2-3-512/139 , Bapunagar Slum Ambernet	1.0	Nil	Satisfactory
81	15/01/14	135	Metro	House tap H.No: 2-3-512/134/1, Bapunagar Slum Ambernet	1.0	Nil	Satisfactory
82	15/01/14	136	Metro	House Tap at D.No : 1-1-632/4/31 Gandhinagar	1.5	Nil	Satisfactory
83	15/01/14	138	Metro	PSP Outside at Domalguda Section	2.0	Nil	Satisfactory
84	15/01/14	140	Metro	House Tap at H.No: 1-3-628 at Kawadiguda	1.5	Nil	Satisfactory
85	15/01/14	142	Metro	PSP Outside at Gandhinagar Section	2.0	Nil	Satisfactory
86	16/01/14	144	Metro	PSP Outside at Aliabad at Aliabad Reservoir	2.0	Nil	Satisfactory
87	16/01/14	146	Metro	House tap at 19-2-24/2 at Alibagh Aliabad	1.5	Nil	Satisfactory
88	16/01/14	147	Metro	Stored water at H.No: 19-3-543/81 at Alibagh Aliabad	Nil	≥1609	Nil	Unsatisfactory	During visit no supply					

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
103	17/1/14	172	Metro	House Tap at 1-4-61/30 Ranganagar Musheerabad	1.5	Nil	Satisfactory
104	18/1/14	173	Metro	Outlet tap at Thattikhana Section Reservoir	1.0	Nil	Satisfactory
105	18/1/14	174	Metro	PSP at 8-2-293/91/1 Sri Venkateshwaranagar Slum Banjara Hills	1.0	Nil	Satisfactory
106	18/1/14	176	Metro	House Tap at 8-2-293/205, Sri Venkateshwaranagar Slum Banjara Hills	1.0	Nil	Satisfactory
107	18/1/14	177	Metro	Outlet tap at S R Nagar Section Reservoir	1.0	Nil	Satisfactory
108	18/1/14	179	Metro	PSP at H.No: 6-3-709/A/8/B Lower Panjagutta Slum	1.0	Nil	Satisfactory
109	18/1/14	181	Metro	PSP outlet at ELSR Prakashnagar S/R , Somajiguda	1.0	Nil	Satisfactory
110	18/1/14	183	Metro	House Tap pit at 22-2-815/1, Siddipetabasti, Noorkhan Bazar	1.5	Nil	Satisfactory
111	18/1/14	185	Metro	PSP near H.NO: 18-7-423/A/325/5, Amannagar (B) Talabkatta	0.5	Nil	Satisfactory
112	18/1/14	187	Metro	PSP opp 22-3-157/1 Darushifa Section	1.0	Nil	Satisfactory
113	18/1/14	189	Metro	PSP opp 23-6-312, Sultan Shahi road Mogalpura	1.0	Nil	Satisfactory
114	18/1/14	191	Metro	PSP near H.No: 17-4-392, Matha Ki Kidiki	1.0	Nil	Satisfactory
115	20/1/14	192	Metro	House Tap at 4-41-172 at Papireddy nagar Qutbullapur Municipality	2.0	Nil	Satisfactory
116	20/1/14	194	Metro	Tap inside at Jagadgirigutta Section	2.0	Nil	Satisfactory
117	20/1/14	196	Metro	House Tap at 42-587/1, at Mysamma nagar, Jagadgirigutta	1.5	23	Nil	Unsatisfactory	25-2-14	612	0.2	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
164	25/1/14	271	Metro	Housae tap at 12-13-852/5/A Gokulnagar , Tarnaka	1.0	Nil	Satisfactory
165	25/1/14	272	Metro	PSP at H.No: 8-5-154 at Durganagar Mylardevpally	1.5	Nil	Satisfactory
166	25/1/14	274	Metro	House tap at D.No : 7-3-67/5 at Budvel Rajendranagar	1.5	Nil	Satisfactory
167	25/1/14	275	Metro	House tap at H.No: 7-3-66/22/1/1/ Sri Ramnagar , Budvel	1.5	Nil	Satisfactory
168	25/1/14	277	Metro	Tap Inside at Miralam Filter	2.0	Nil	Satisfactory
169	25/1/14	279	Metro	PSP at 9-2-28/A/13/A (Outlet) Jahanuma Reservoir	2.0	Nil	Satisfactory
170	25/1/14	280	Metro	PSP Outside (Inlet) Jahanuma Reservoir	1.0	Nil	Satisfactory
171	25/1/14	282	Metro	PSP at H.No: 19-2-21/11/E/A/1/1 at Kalapattar Maruthinagar	1.5	Nil	Satisfactory
172	25/1/14	283	Metro	Tap Inside at Misrigunj Reservoir	2.0	Nil	Satisfactory
173	25/1/14	285	Metro	Outlet tap water near main gate at Bhagyanagar S/R KPHB	0.1	23	Unsatisfactory	26-2-14	626	1	Nil	Satisfactory
174	25/1/14	286	Metro	Outlet tap water in pump room at IV th Phase KPHB	0.1	Nil	Satisfactory
175	25/1/14	287	Metro	House tap at LIGH KPHB No: 117/11 ,IV Th Phase Quarters	0.1	23	Unsatisfactory	26-2-14	628	Nil	23	Unsatisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
214	31/1/14	348	Metro	PSP at 4-1-42, Hanuman Tekdi, Abids	1.5	Nil	Satisfactory
215	31/1/14	350	Metro	House tap at D.No;4- 4-942/A/1 at Kanda Swamy lane Sultan Bazar	0.2	Nil	Satisfactory

Abstract (first sampling)		Result of Resampling of unsatisfactory samples	BACTERIOLOGICAL STANDARDS OF DRINKING WATER	
Total No. of samples tested for Residual Chlorine in water samples	1825	• Untreated water	Faecal coliforms should be Zero (0) Coliform organism in any one sample should not be more than 10 per 100ml,
Total No. of samples found Residual Chlorine satisfactory	1817		
Total No. of samples found Residual Chlorine Nil	8	• Treated water	Faecal coliforms should be Zero (0) Coliform organism in any one sample should not be more than 4 per 100ml,
Total No. of Samples Collected and tested for Bacteriological quality	215	12(1no resampling not necessary)		
No. of Samples Bacteriologically found satisfactory	203	9	• Un piped Supplies	Coliform organisms should not be more than 10 per 100 ml, Faecal coliforms should be Zero (0)
No. of Samples Bacteriologically found unsatisfactory	12	3		
Testing under process		• Emergency supplies	Coliform Organisms should not be more than 10 per 100 ml, Faecal coliforms should be Zero (0) No Sample should contain E.coli in 100ml.
To be resampled				

