

					Commissioner Muncipal Corporetion warangal										
30	3/1/2014	2738	Md. S	OHSR	at Public Garden Tank Hanam Konda	2.0	Nil	...	Satisfactory
31		2739		Tap	at # 5-1-81 Ambala Road	0.5	Nil	...	Satisfactory
32		2740		Tap	at # 5-2-110.....do.....	0.5	Nil	...	Satisfactory
33		2741		Tap	at # 5-2-26 Bokala gadda	0.5	Nil	...	Satisfactory
34		2742		Tap	at # 5-2-137 Bokala gadda	0.5	Nil	...	Satisfactory
35		2743		Tap	at # 5-5-42 kammari wada	0.5	Nil	...	Satisfactory
36		2744		Tap	at # 5-6-112,Lashkar Bazar	0.5	Nil	...	Satisfactory
37		2745		Tap	at # 5-6-141,Lashkar Bazar	0.5	Nil	...	Satisfactory
38		2746		Tap	at # 5-9-87kishan pura	0.5	Nil	...	Satisfactory
39		2747		Tap	at # 5-9-162.....do.....	0.5	Nil	...	Satisfactory
					Commissioner Muncipal Corporetion warangal										
40	6/1/2014	2748	Md. S	OHSR	at Khazipet Reservior	2.0	Nil	...	Satisfactory
41		2749		Tap	at # 25-10-16 Ambedker nagar	0.5	Nil	...	Satisfactory
42		2750		Tap	at # 25-10-41 Ambedker nagar	0.5	Nil	...	Satisfactory
43		2751		Tap	at # 25-10-98.....do.....	0.5	Nil	...	Satisfactory
44		2752		Tap	at # 25-6-199/1 St.An School	0.5	Nil	...	Satisfactory
45		2753		Tap	at # 25-6-223near.....do.....	0.5	Nil	...	Satisfactory
46		2754		Tap	at # 25-6-246.....do.....	0.5	Nil	...	Satisfactory
47		2755		Tap	at # 1-6-25 Jublee market	0.5	Nil	...	Satisfactory
48		2756		Tap	at # 1-6-39.....do.....	0.5	Nil	...	Satisfactory
49		2757		Tap	at # 1-6-81.....do.....	0.5	Nil	...	Satisfactory
					Panchayat Secretary,Gp:Durgam Peta,Mndl:Atmakur,Dist:warangal										
50	8/1/2014	2758	BCS	BW	(HP)at Canal Bridge Main road Durgam	...	Nil	...	Satisfactory
51		2759		BW	(HP)at Pasra gonda cross.....do.....	...	20	...	UnSatisfactory	Resampling not necessary					
52		2760		BW	(HP)at MP School Agrampad road	...	Nil	...	Satisfactory
53		2761		OW	(DP) at Pinnakunta.....do.....	nil	>1609	...	UnSatisfactory	Resampling not necessary					
54		2762		OHSR	at GP office	nil	>1609	...	UnSatisfactory	To be resampled					
					Panchayat Secretary,Gp:Urugonda,Mndl:Atmakur,Dist:warangal										
55		2763		OW	at Bathu Kama kunta	nil	>1609	...	UnSatisfactory	To be resampled					
56		2764		OHSR	at ZPHSchool	nil	>1609	...	UnSatisfactory						
57		2765		Tap	atdo.....	nil	>1609	...	UnSatisfactory						
					Excutive officer Sri Mallikarguna Swamy Devasthanam Inavolu Dist:warangal										
58	8/1/2014	2766	MJN	OW	at back side of Temple	nil	Nil	...	Satisfactory
59		2767		BW	at back side of Temple	...	Nil	...	Satisfactory
60		2768		BW	East side of Temple	...	4.0	...	UnSatisfactory	Resampling not necessary					
61		2769		BW	near M.complex (Road side)	...	20.0	...	UnSatisfactory						
62		2770		BW	near Thanda Venkanna (exPACS)	...	Nil	...	Satisfactory
63		2771		cistern	No.1 back side (west side)of Temple	0.5	Nil	...	Satisfactory

64		2772		cistern	No.2do.....	0.5	Nil	Satisfactory
65		2773		cistern	No.3.....do.....	0.5	Nil	Satisfactory
66		2774		cistern	No.4.....do.....	0.5	Nil	Satisfactory
67		2775		cistern	No.5.....do.....	0.5	Nil	Satisfactory
68		2776		cistern	No.6.....do.....	0.5	Nil	Satisfactory
69		2777		cistern	(Big) near M.complex	0.5	Nil	Satisfactory
70		2778		cistern	(Big) near temple	0.5	Nil	Satisfactory
					Panchayat Secretary, Gp:Machapur, Mndl:Govindarao peta, Dist:warangal										
71	8/1/2014	2779	K.S	BW	(DP) at Chinthala cheruvu, Machapur	...	Nil	Satisfactory
72		2780		OHSR	(BW)water in UP School	nil	>1609	Unsatisfactory	To be resampled					
73		2781		Tap	at Allenki Sridhar House	nil	>1610	Unsatisfactory	resampling not necessary					
74		2782		Tap	at Pinninti Madhu House	nil	>1611	Unsatisfactory						
75		2783		Tap	at Kummari kuntla Rajaiah House	nil	>1612	Unsatisfactory						
76		2784		Tap	at Darangula Raju House	nil	>1613	Unsatisfactory						
77		2785		BW	(HP) near kandugula sarojana House	...	>1614	Unsatisfactory						
78		2786		BW	(HP) near Bojja Yellamma House	Unsatisfactory						
79		2787		BW	(HP)near Aluvala kanakaiah House	...	Nil	Satisfactory
80		2788		BW	(HP) near Daripelli Perumaiah House	...									
					Assistant Engneer Public Health Setor water Supply, Bhadrachalam, Dist:Khammam										
81	11/1/2014	2789	Md.S		at Ranganayaka Gutta FB	2.0	Nil	Satisfactory
82		2790			P.S.P at Rajaveedhi	2.0	Nil	Satisfactory
83		2791			P.S.P near Temple	1.5	Nil	Satisfactory
84		2792			OHSR Pandavula Gutta	2.0	Nil	Satisfactory
85		2793			P.S.P near old CPM office	1.5	Nil	Satisfactory
86		2794			at #13-1-107 Revarge colony	1.5	Nil	Satisfactory
87		2795			P.S.P at chapta Deguva	1.5	Nil	Satisfactory
88		2796			Tap at super Bazar	1.5	Nil	Satisfactory
89		2797			at #9-2-65 kothapeta	1.5	Nil	Satisfactory
90		2798			at #9-1-178 shanthi nager	1.5	Nil	Satisfactory
					Excutive officer Sri -Setharama swamy temple Bhadrachalam Dist: khammam										
91		2799		BW	Tap at Annadana Satram, Bhdrachalam Devastanam	nil	>1609	Unsatisfactory	resampling not necessary					
92		2800		Treated	water from puri fair atdo.....	...	Nil	Satisfactory
					Commissioner Muncipal Corporetion warangal										
93	16/1/2014	2801	Md.S	OHSR	at Nakkalagutta reseruior	2.0	Nil	Satisfactory
94		2802		Tap	at #2-4-436 Ram Nagar	1.0	Nil	Satisfactory
95		2803		Tap	at # 2-4-81.....do.....	1.0	Nil	Satisfactory
96		2804		Tap	at # 2-4-478.....do.....	1.0	Nil	Satisfactory
97		2805		Tap	at # 2-4-493.....do.....	1.0	Nil	Satisfactory
98		2806		Tap	at #2-4-1063 Gokul Nagar	1.0	Nil	Satisfactory
99		2807		Tap	at # 2-4-893.....do.....	1.0	Nil	Satisfactory
100		2808		Tap	at # 1-7-1131 Srinivas nagar	1.0	Nil	Satisfactory
101		2809		Tap	at #1-7-1191.....do.....	1.0	Nil	Satisfactory
102		2810		Tap	at #1-7-1086.....do.....	1.0	Nil	Satisfactory

					Panchayat Secretary, Gp:Gudeppad, Mndl:Atmakur, Dist:warangal														
103	16/1/2014	2811	K.S	OHT	(OW) water in UP School	nil	>1609	...	Satisfactory
104		2812		Tap	at Kanthala Kishan reddy House	nil	>1610	...	Satisfactory
105		2813		Tap	at Thinneti Indra Reddy House	nil	>1611	...	Satisfactory
106		2814		Tap	at Maidham Rajaiiah House	nil	>1612	...	Satisfactory
107		2815		Raw	(OW) at Sc colony	nil	>1613	...	Satisfactory
108		2816		Treated	at GP office	...	>1614	...	Satisfactory
109		2817		OW	at Gudeppad cheruvu	nil	>1615	...	Satisfactory
110		2818		BW	(HP) at Peddi Reddy Narsi Reddy House	...	>1616	...	Satisfactory
111		2819		BW	HP) at Boddu rai	...	>1617	...	Satisfactory
112		2820		BW	(HP) atsc colony	...	>1618	...	Satisfactory
					Panchayat Secretary, Gp:Agramphard, Mndl:Atmakur, Dist:warangal														
113	17/1/2014	2821	Md.S	BW	(HP) near Vishwa Bharathi School	...	Nil	...	Satisfactory
114		2822		BW	(HP) at sukka saraiah cans near chamma	...	>1609	...	Unsatisfactory	resampling not necessary									
115		2823		BW	(HP) near Sammaka sarakka gadde	...	>1609	...	Unsatisfactory	resampling not necessary									
116		2824		BW	(HP) at Chavla pally near Temple Road	...	Nil	...	Satisfactory
117		2825		BW	(HP) near Cistern Temple main Road	...	>1609	...	Unsatisfactory	resampling not necessary									
118		2826		BW	(HP) near Cheruvu mathadi sc colony	...	Nil	...	Satisfactory
119		2827		BW	(HP) near church sc colony	...	Nil	...	Satisfactory
120		2828		BW	(HP) near nNudari Sammaiah House sc col	...	Nil	...	Satisfactory
121		2829		BW	OHSR near Gp office	nil	>1609	...	Unsatisfactory	resampling not necessary									
122		2830		BW	Treated water from RO purifaier at sur	...	Nil	...	Satisfactory
123		2831		BW	(HP)near Hanuman Temple	...	>1609	...	Unsatisfactory	resampling not necessary									
					Panchayat Secretary, Gp:Akkempeta, Mndl:Atmakur, Dist:warangal														
124	17/1/2014	2832	BCS	OW	at Sri Ramula kunta	nil	>1609	...	Unsatisfactory	resampling not necessary									
125		2833		OHSR	at Agramphad Road	nil	>1609	...	Unsatisfactory	resampling not necessary									
126		2834		BW	(HP)at JanagamSadaiaha House	...	Nil	...	Satisfactory
127		2835		BW	(HP)at Nagaiah palli road	...	Nil	...	Satisfactory
128		2836		BW	(HP) at Somala Mogili House	...	>1609	...	Unsatisfactory	resampling not necessary									
129		2837		BW	(HP) at seeliveru sambhaiah house pedda	...	>1610	...	Unsatisfactory	resampling not necessary									
130		2838		BW	HP at GP office	...	>1611	...	Unsatisfactory	resampling not necessary									
131		2839		BW	(HP)at samula Raju bus standdo.....	...	Nil	...	Satisfactory
132		2840		BW	(HP)at Md.Karim housedo.....	...	Nil	...	Satisfactory
133		2841		BW	(HP)at k.agaiiah hosedo.....	...	>1609	...	Unsatisfactory	resampling not necessary									
134		2842		BW	(HP)at bridge.....do.....	...	Nil	...	Satisfactory
					Commissioner Muncipal Corporetion warangal														
135	20/1/14	2843	BCS	Tap	at # 10-1-11, Govinda Rajula gutta, Aruja	0.5	>1609	...	Unsatisfactory	resampling not necessary									
136		2844		Tap	at #10-1-220.....do.....	0.5	>1609	...	Unsatisfactory	resampling not necessary									
137		2845		Tap	at #10-1-121.....do.....	0.5	Nil	...	Satisfactory
138		2846		Tap	at #10-1-263.....do.....	0.5	>1609	...	Unsatisfactory	resampling not necessary									
139		2847		Tap	at #10-1-178.....do.....	0.5	>1610	...	Unsatisfactory	resampling not necessary									

140		2848		Tap	at #10-1-300.....do.....	0.5	>1611	Unsatisfactory						
141		2849		Tap	at #10-2-2250.....do.....	0.5	Nil	Satisfactory
142		2850		Tap	at #10-2-141.....do.....	0.5	Nil	Satisfactory
143		2851		Tap	at #10-2-116.....do.....	0.5	Nil	Satisfactory
144		2852		Tap	at #10-2-55.....do.....	0.5	Nil	Satisfactory
					Panchayat Secretary, Gp:Mallampally, Mndl:Mulugu,Dist:warangal										
145	20/1/14	2853	Md.S	BW	water near Ayurvedic Hospital	2.0	>1609	Unsatisfactory	resampling not necessary					
146		2854		BW	at ZPS School	2.0	Nil	Satisfactory
147		2855		BW	(DP)at Angani wada	...	Nil	Satisfactory
148		2856		BW	(DP)at shanthi nagar	...	>1609	Unsatisfactory	resampling not necessary					
149		2857		BW	(DP)at Humai nagar mai road	...	>1609	Unsatisfactory						
150		2858		BW	(DP)at Humai nagar , near balavikas school	...	>1609	Unsatisfactory						
151		2859		BW	(DP)near Govt.UP school kummari wada	...	7.0	Unsatisfactory						
152		2860		BW	(DP)near Hanuman temple.....do.....	...	4.0	Unsatisfactory						
153		2861		BW	(HP)water beside cheruvu manchinilla p	...	>1609	Unsatisfactory						
154		2862		BW	(DP)near Hanuman temple manchinilla pally	...	>1609	Unsatisfactory						
					Medical Officer,Tribal Primeses,Health Center,Azam Nagar,Bhoopalapally										
155	20/1/14	2863	self	BW	(HP)at Dudekulapally	...	Nil	Unsatisfactory	resampling not necessary					
156		2864		BW	at DNT schooldo.....	...	>1609	Unsatisfactory						
157		2865		BW	(HP)at Gollabudharam High School	...	>1609	Unsatisfactory						
158		2866		BW	at DNT School Rampur	...	>1609	Unsatisfactory						
					Panchayat Secretary, Gp:& Mndl: Mulugu,Dist:warangal										
159	21/1/14	2867	BCS	OHT	at Geenukula Gadda Mulugu	0.5	Nil	Satisfactory
160		2868		Tap	psp at pakeer wada mulugu	0.2	Nil	Satisfactory
161		2869		OHT	at main road Gattamma Temple	0.5	Nil	Satisfactory
162		2870		OW	at main road Jakaram area mulugu	0.5	Nil	Satisfactory
163		2871		BW	(HP) near GP open well area	...	>1609	Unsatisfactory	resampling not necessary					
164		2872		Tap	psp at saina Gudi main road	0.2	Nil	Satisfactory
165		2873		BW	(HP) MH no 379,at Gattamma Temple	...	Nil	Satisfactory
166		2874		Cystran	at (RWS) Ralla chettu	nil	93	Unsatisfactory	resampling not necessary					
167		2875		BW	(HP) Mh.381do.....	...	15	Unsatisfactory						
168		2876		Cystran	at Letreen shead Gattamma Temple Mulugu	nil	>1609	Unsatisfactory						
169		2877		BW	(HP) MH.384do.....	...	Nil	Satisfactory
170		2878		BW	(HP) MH.383do.....	...	Nil	Satisfactory
171		2879		BW	(HP) MH-382 mai road.....do.....	...	Nil	Satisfactory
					Panchayat Secretary, Gp:Jakaram, Mndl:Mulugu,Dist:warangal				
172	22/1/14	2880	K.S	BW	(HP)water in Govt. Primary School Jakaram	...	>1609	Unsatisfactory	resampling not necessary					

173		2881		BW	(DP) water near Muthyala Ilaiah Agri.land	...	>1610	...	UnSatisfactory	resampling not necessary					
174		2882		BW	(DP) water at main road plant estat	...	Nil	...	Satisfactory
175		2883		BW	(HP) water Gugulothu Ravi house	...	Nil	...	Satisfactory
176		2884		BW	(HP) water near LadunuriSaraiah house	...	>1609
177		2885		BW	(HP) water near kalvala Dhurgaiah house	...	Nil	...	Satisfactory
178		2886		BW	(HP) water near Gandrothu Rajaiah House	...	240	...	UnSatisfactory	resampling not necessary					
179		2887		BW	(HP) water near Manchi chandra Mogili House	...	75	...	UnSatisfactory						
180		2888		BW	(HP) water near Gandra Dhamoder house	...	Nil	...	Satisfactory
181		2889		BW	(HP) water near sudhamallu Papaiah house	...	Nil	...	Satisfactory
182		2890		BW	(HP) water Ghandroth Prathap House	...	>1609	...	UnSatisfactory	resampling not necessary					
183		2891		BW	(HP) water main road bus stand Jakaram	...	93	...	UnSatisfactory						
184		2892		BW	(HP) water near Orusu Mallaiiah house	...	Nil	...	Satisfactory
					Superintendent of Engineer (RWS) ZP Premises, warangal				
185	24/1/14	2893	B&sta	Tap	at road side ,Gattamma Temple		>1609	...	UnSatisfactory	resampling not necessary					
186		2894		BW	(HP) MH-381.....do.....		Nil	...	Satisfactory
187		2895		Tap	near Toilets.....do.....		>1609	...	UnSatisfactory	resampling not necessary					
188		2896		BW	(HP) MH-384,.....do.....		Nil	...	Satisfactory
189		2897		OW	water at H.No.2-04 Madaram		>1609	...	UnSatisfactory	resampling not necessary					
190		2898		OW	water H.No-2-03.....do.....		>1609	...	UnSatisfactory						
191		2899		OW	water opp to H.No2-07.....do.....		>1610	...	UnSatisfactory						
192		2900		OW	water at H.No-2-23.....do.....		>1611	...	UnSatisfactory						
193		2901		BW	(HP) MH-19,Sammakka Temple Pranham,Madaram		>1612	...	UnSatisfactory						
194		2902		OW	at H.No-2-33, Madaram		>1613	...	UnSatisfactory						
195		2903		OW	at H.No-c/39, Madaram		>1614	...	UnSatisfactory						
196		2904		BW	(HP) MH-22.....do.....		>1615	...	UnSatisfactory						
197		2905		OW	near H/o Porike Venkat Rao.....do.....		>1616	...	UnSatisfactory						
198		2906		OW	at H.No2-45/A,Bhukya Saraiahdo.....		>1617	...	UnSatisfactory						
199		2907		OW	at Alam Ram Murthy Housedo.....		>1618	...	UnSatisfactory						
200		2908		OW	Beside 2-45/A, Porika kyka		>1619	...	UnSatisfactory						
201		2909		BW	(HP) MH-23,cheruvu road Madaram		>1609	...	UnSatisfactory						
202		2910		BW	(HP)do.....		Nil	...	Satisfactory
203		2911		BW	(HP) MH-24 in fields		Nil	...	Satisfactory
204		2912		BW	(HP) near H.No.2-46/A Madaram		>1609	...	UnSatisfactory	resampling not necessary					
205		2913		Treated	(RO)at Eswar House Madaram		>1609	...	UnSatisfactory						
206		2914		BW	(HP) MH-1 Madaram		>1609	...	UnSatisfactory						
207		2915		BW	tap at sink opp to ITDA camp office Madaram		>1609	...	UnSatisfactory						

208		2916		BW	(HP) MH-8, opp to sri Sammakka saralamma prabhodu center Madaram		Nil	Satisfactory
209		2917		BW	(HP) opp to hemachanrda Laxmi narasimha Templedo.....		Nil	Satisfactory
210		2918		BW	(HP) back side to IDTA ccamp office		Nil	Satisfactory
211		2919		BW	(HP) MH-4 in fielda opp to Temple.....do.....		28	Unsatisfactory	resampling not necessary					
212		2920		BW	(HP) MH-5Ashrama Patashala madaram		21	Unsatisfactory						
213		2921		BW	(HP) MH-6,do.....		43	Unsatisfactory						
214		2922		BW	(HP) MH-54 infield road side madaram		28	Unsatisfactory						
215		2923		Raw	at Jampann vagumadaram		>1609	Unsatisfactory						
216		2924		Intake	welldo.....		>1609	Unsatisfactory						
217		2925		BW	(HP) MH-120, Kothuru road		Nil	Satisfactory
218		2926		BW	(HP) MH-118,do.....		Nil	Satisfactory
219	24/1/2014	2927		OW	at Neerukulla cross road ,Atmakur	nil	>1609	Unsatisfactory	resampling not necessary					
220		2928		BW	Cystran at kallu manduva kataksha pur	nil	>1609	Unsatisfactory						
221		2929		BW	at cheruvu kataksha pur	...	3	Unsatisfactory						
222		2930		BW	at bus stand main road mallam pally	...	3	Unsatisfactory						
223		2931		BW	(HP) at Gp officedo.....	...	Nil	Satisfactory
224		2932		BW	(HP) at bus stand pandikunta road	...	Nil	Satisfactory
225		2933		BW	(HP) MH-367 javahar nagar	...	Nil	Satisfactory
226		2934		BW	(HP) MH- 368, Gattamma Temple,do.....	...	Nil	Satisfactory
227		2935		BW	(HP) MH-369do..... .back side	...	Nil	Satisfactory
228		2936		BW	(HP) MH-364 at Primary School Machapur	...	Nil	Satisfactory
229		2937		BW	(HP) MH-363 padmakirando.....	...	Nil	Satisfactory
230		2938		BW	(HP)MH-360 Anganivadi chalvai	...	Nil	Satisfactory
231		2939		BW	(HP)MH-361 Aziz Housedo.....	...	Nil	Satisfactory
232		2940		BW	(HP)MH- 358 Ramesh Housedo.....	...	Nil	Satisfactory
233		2941		OHSR	tap at ZPH School atdo.....	nil	>1609	Unsatisfactory	To be resampled					
234		2942		BW	sitex tank waterdo.....	nil	Nil	Satisfactory
235		2943		BW	(HP)at kasula sadanadam house.....do.....	...	Nil	Satisfactory
236		2944		BW	(HP)MH-349 babu house.....do.....	...	Nil	Satisfactory
237		2945		BW	(HP) babu housedo.....	...	Nil	Satisfactory
238		2946		BW	(HP) MH-262 Hanuman temple pasra		Nil	Satisfactory
239		2947		BW	(HP)at ZPHSchool pasra	...	Nil	Satisfactory
240		2948		OHSR	tap at ZPHSchool at chalwai	nil	>1609	Unsatisfactory	resampling not necessary					
241		2949		BW	(HP) at Nanga sammaiah Pasra		Nil	Satisfactory
242		2950		BW	(HP) at Nethaji Nagar Pasra		11	Unsatisfactory	resampling not necessary					
243		2951		BW	(HP)MH-257 Rangava patnam cross Pasra		>1609	Unsatisfactory						
244		2952		BW	(HP)MH-256 Narlapur road side		Nil	Satisfactory
245		2953		BW	(HP)MH-255 at Project Nagar		Nil	Satisfactory
246		2954		BW	cystran at Govt.TW Schooldo.....	nil	28	Unsatisfactory	resampling not necessary					
247		2955		BW	(HP)MH-250 Angani wadi	...	Nil	Satisfactory
248		2956		BW	(HP)MH-244 at kandukuri bixamaiah vengala	...	Nil	Satisfactory
249		2957		BW	(HP) at Anganiwadi center	...	43	Unsatisfactory	resampling not necessary					
250		2958		BW	(HP)MH-236new	...	Nil	Satisfactory
251		2959		BW	(HP)MH-234 Tallaphad BOT sit	...	20	Unsatisfactory

252		2960		BW	(HP)MH-230, chinthal cross road	...	Nil	...	Satisfactory											
253		2961		BW	(HP)MH-227 byakka peta cross	...	Nil	...	Satisfactory											
254		2962		BW	(HP)MH-192 kalavapally chek post Narlapur	...	20	...	Unsatisfactory											
255		2963		BW	(HP)MH-191do.....	...	Nil	...	Satisfactory
256		2964		BW	(HP)MH-189do.....	...	>1609	...	Unsatisfactory	resampling
257		2965		BW	(HP)MH-148.....do.....	...	Nil	...	Satisfactory
258		2966		BW	(HP)MH-149.....do.....	...	Nil	...	Satisfactory
259		2967		BW	(HP)MH-146 at Kannepally chek post	...	>1609	...	Unsatisfactory Unsatisfactory	resampling
260		2968		BW	(HP)MH-147do.....	...	28	...	>1609
261		2969		BW	(HP)MH-145.....do.....	...	Nil	...	Satisfactory
262		2970		BW	(HP)MH-144.....do.....	...	Nil	...	Satisfactory
263		2971		BW	(HP)MH-143 B.Sadhaiah kothur	...	7	...	Unsatisfactory
264		2972		BW	(HP)MH-140,Krishna housedo.....	...	Nil	...	Satisfactory
265		2973		BW	(HP)MH-132 Donthu raji Reddy House Kothur	...	Nil	...	Satisfactory
266		2974		BW	(HP)MH-131, chinthala saraiah house Kothur	...	Nil	...	Satisfactory
267		2975		BW	(HP)MH-129, Pochamma TempleKothur	...	Nil	...	Satisfactory
268		2976		BW	(HP)MH-121, opp. Sub station Kothur	...	Nil	...	Satisfactory
269		2977		BW	(HP)MH-120, thirumala hospital Kothur	...	Nil	...	Satisfactory
270		2978		BW	(HP)MH-148,.....do.....	...	4	...	Unsatisfactory
271		2979		BW	(HP) Saralamma Arch Urattam	...	11	...	Unsatisfactory
272		2980		BW	(HP)MH-105, Kannepelly cross Urattam	...	Nil	...	Satisfactory
273		2981		BW	(HP) P.Narsaiah kanne pelly	...	>1609	...	Unsatisfactory
274		2982		BW	(HP)MH-107 at saralamma Temple	...	Nil	...	Satisfactory
275		2983		BW	(HP)MH-111, at solam Krishnaiah Kannepelly	...	Nil	...	Satisfactory
276		2984		BW	(HP) stoopam madaram	...	11	...	Satisfactory
277		2985		BW	(HP)MH-87, T.Laxmi House Urattam	...	Nil	...	Satisfactory
278		2986		BW	(HP)MH-89 at PS School Urattam	...	Nil	...	Satisfactory
279		2987		BW	(HP)MH-91,at Korem Narsaiah Urattam	...	Nil	...	Satisfactory
280		2988		BW	(HP)MH-15Chelukala Gutta	...	Nil	...	Satisfactory
281		2989		BW	(HP)MH-75 at RMP Dr. Reddy gudem	...	Nil	...	Satisfactory
					Dy Genaral Manager (civil) Sco Ltd. Rudrampur ,Khammam
282	27/1/2014	2990	self	Treated	water at VK -7 FB	...	Nil	...	Satisfactory
283		2991		Tap	at GM Office	...	Nil	...	Satisfactory
284		2992		Tap	at GP FB	...	Nil	...	Satisfactory
285		2993		Tap	at GP FB	...	Nil	...	Satisfactory
286		2994		Tap	at Q.No.T2 68 D Gowtham pur	...	Nil	...	Satisfactory
287		2995		Tap	at Q.No.DA 887 Nehuru Bhasthi	...	Nil	...	Satisfactory
288		2996		Tap	at 2- Incline FB	...	Nil	...	Satisfactory
289		2997		Tap	at 3- Incline FB	...	Nil	...	Satisfactory
290		2998		Tap	at Q.No.	...	Nil	...	Satisfactory
291		2999		Tap	at GKOCP	...	Nil	...	Satisfactory
292		3000		Tap	at Q.No. 2997	...	Nil	...	Satisfactory

resampling not necessary

					Panchayat Secretary, Gp:& Mndl:Govindarao pet, Dist:warangal
293	27/1/2014	3001	Md.S	BW	OHSRwater bisid gat Jr.college	nil	Nil	Satisfactory
294		3002		BW	(DP)water beside gat Raghava patnam	nil	Nil	Satisfactory
295		3003		BW	(DP) at Rauga puram	nil	Nil	Satisfactory
296		3004		BW	(DP)at Eppalagadda	nil	Nil	Satisfactory
297		3005		BW	(HP)water near bus stand	nil	Nil	Satisfactory
298		3006		BW	(HP) at NTR colony opp.yadagiri house	nil	Nil	Satisfactory
299		3007		BW	(HP)at opp V rama das house	nil	Nil	Satisfactory
300		3008		BW	Cystran water near bus stand	nil	Nil	Satisfactory
301		3009		BW	Cystran water beside water tank	nil	Nil	Satisfactory
302		3010		BW	Cystran at opp Jrama ram house	nil	1100	Unsatisfactory	resampling not necessary					
303		3011		BW	at oppdo.....	nil	43	Unsatisfactory						
					Panchayat Secretary, Gp:Chalwai, Mndl:Govindarao petaDist:warangal		
304	28/1/14	3012	BCS	OW	at somla gadda	nil	Nil	Satisfactory
305		3013		OHSR	at GP office	0.2	Nil	Satisfactory
306		3014		Tap	at main road Gp office	0.2	Nil	Satisfactory
307		3015		Tap	at ZPHschool	0.2	Nil	Satisfactory
308		3016		BW	(HP) at podi shetti mallaiah house	...	Nil	Satisfactory
309		3017		BW	(HP)at pala kendram main road	...	Nil	Satisfactory
310		3018		BW	(HP) at Poshamma gudi	...	15	Unsatisfactory	resampling not necessary					
311		3019		BW	(HP) at Maddineni venkanna house	...	>1609	Unsatisfactory						
312		3020		BW	(HP) at Velu konda sammaiah house	...	Nil	Satisfactory
313		3021		BW	(HP) at N.Boomaiah house	...	Nil	Satisfactory
314		3022		BW	(HP)at St.hostel chalwai	...	>1609	Unsatisfactory	resampling not necessary					
					S.E (civil) KGM civil Engineering Department Kothagudam									
315	29/1/2014	3023	self	maine	tap at pump house	2.0	Nil	Satisfactory
316		3024		BW	tap at main road	1.5	Nil	Satisfactory
317		3025		maine	tap at C-Barrac	0.2	Nil	Satisfactory
318		3026		maine	tap at DA -347	0.2	Nil	Satisfactory
319		3027		maine	tap at female ward	0.2	Nil	Satisfactory
320		3028		maine	tap at Transit guest house	0.2	Nil	Satisfactory
					Dy Genaral Manager (civil) Sco Ltd. Goleti Mndl.Rebbana				
321	29/1/2014	3029	MD.S	maine	water from RO purifair at GM office	...	Nil	Satisfactory
322		3030		maine	at goleti tounship FB	2.0	Nil	Satisfactory
323		3031		maine	water from Q.NoD-106 goleti tounship	...	Nil	Satisfactory
324		3032		maine	water from RO purifair atkhirigura ocp	...	15	Unsatisfactory	resampling not necessary					
325		3033		maine	madharam goleti tounship	...	>1609	Unsatisfactory						
326		3034		maine	water from RO purifair at Dorli ocp-2	...	Nil	Satisfactory
327		3035		maine	water from RO purifair at 1-A Incline F	...	Nil	Satisfactory
328		3036		maine	water from RO purifair at madharam goleti tounship	2	Nil	Satisfactory
329		3037		maine	water from Q.No. c-16 at madharam goleti tounship	1	Nil	Satisfactory

330		3038		maine	water from Ram Mandir FB	2	Nil	Satisfactory
331		3039		Godavari	water from Ram Mandir FB	2	Nil	Satisfactory
332		3040		Godavari	water from RO purifair at aria Hospital	...	Nil	Satisfactory
333		3041		Godavari	at shanti khani FB	2	Nil	Satisfactory
334		3042		Godavari	at Q.No. C-26 at station road colony	1	Nil	Satisfactory
					Dy Genaral Manager (civil) Sco Ltd. Sri Ram pur Aria Adilabads				
335	29/1/2014	3043	self	Tap	SRP-RO systam water		Nil	Satisfactory
336		3044		Tap	at SRP -3 RO systam		Nil	Satisfactory
337		3045		Tap	at RK-5 Incline RO systam		Nil	Satisfactory
338		3046		Tap	at RK-6 RO systam		Nil	Satisfactory
339		3047		Tap	at at RK-8.....do.....		Nil	Satisfactory
340		3048		Tap	at RK-7 In cline		Nil	Satisfactory
341		3049		Tap	at RK NT RO systam		Nil	Satisfactory
342		3050		Tap	at 1K 1& 1Ado.....		Nil	Satisfactory
343		3051		Tap	at SRP-ocp RO systam		Nil	Satisfactory
344		3052		Tap	at SRP_ 1INcline		>1609	Unsatisfactory	resampling not necessary					
					Commissioner Muncipal Corporetion warangal				
345	31/1/2014	3053	Md.S	OHSR	water at subedari riservaioir	2	Nil	Satisfactory
346		3054		psp	at out side riservaioir	0.5	Nil	Satisfactory
347		3055		Tap	at # 2-10-226Teachers colony	0.5	Nil	Satisfactory
348		3056		Tap	at # 2-10-241,.....do.....	0.5	Nil	Satisfactory
349		3057		Tap	at # 2-10-253.....do.....	0.5	Nil	Satisfactory
350		3058		Tap	at # 2-10-271.....do.....	0.5	Nil	Satisfactory
351		3059		Tap	at # 2-7-1228,kanaka durga colony	0.5	Nil	Satisfactory
352		3060		Tap	at # 2-7-1236.....do.....	0.5	Nil	Satisfactory
353		3061		Tap	at # 2-7-1256.....do.....	0.5	Nil	Satisfactory
354		3062		Tap	at # 2-7-1281.....do.....	0.5	Nil	Satisfactory

ABSTRACT

Total No of samples tested for Residual Chlorine in water samples	256
Total No of Samples found Residual Chlorine satisfactory	210
Total No of samples found residual chlorine Nil	46
Total No of samples collected and tested for Bacteriological quality	354
No of samples Bacteriologically found Satisfactory	247
No of samples Bacteriologically found Unsatisfactory	107
Under process	7(100 resaplir not necessary