

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
29	05/05/14	1324	Metro	PSP outside at Gandhinagar S/R Ashoknagar , Musheerabad	1.0	Nil	Satisfactory
30	05/05/14	1326	Metro	House tap at (pit) H.No: 1-1-652/K/205 Street No: I, Musheerabad	0.5	Nil	Satisfactory
31	05/05/14	1328	Metro	Tanker Filling Point at LIC Colony Domalguda S/R	1.5	Nil	Satisfactory
32	05/05/14	1329	Metro	House tap pit at 1-1-652/4/25 Sabarmati Gandhinagar	1.0	Nil	Satisfactory
33	05/05/14	1331	Metro	Tanker Filling Point (outside) Narayanguda S/R	1.5	Nil	Satisfactory
34	05/05/14	1332	Metro	PSP at 21-2-415 Mehaboob Chowk Tower Charminar	1.0	Nil	Satisfactory
35	06/05/14	1333	Metro	PSP at 21-6-771 Chelapura ,Imli Ka Jhaad slum	1.0	Nil	Satisfactory
36	06/05/14	1335	Metro	Outlet tap at Misrigunj S/R	1.0	Nil	Satisfactory
37	06/05/14	1337	Metro	Tanker Filling Point at Shivam S/R	1.0	Nil	Satisfactory
38	06/05/14	1339	Metro	Tap inside Boiguda S/R	Nil	≥1609	Nil	Unsatisfactory	To be Resampled (During visit no supply)					
39	06/05/14	1341	Metro	Tap inside Srinivasanagar S/R	0.5	Nil	Satisfactory
40	06/05/14	1343	Metro	PSP at 12-11-801 Pochamma Temple Warasiguda	0.2	23	Nil	Unsatisfactory	1948	27-6-14	1	Nil		Satisfactory
41	07/05/14	1344	Metro	House tap pit GHMC 1611 Street No: 20 Suryanagar , Chikkadpally.	2.0	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
55	08/05/14	1367	Metro	Tap inside Rajendra Nagar Section	1.0	Nil	Satisfactory
56	08/05/14	1369	Metro	PSP opp 1-3-21/5 at Budvel	1.0	Nil	Satisfactory
57	08/05/14	1371	Metro	PSP near Kaman NIRD Rajendranagar	1.0	23	Nil	Unsatisfactory	2/7/2014	1978	1.5	Nil	Satisfactory
58	08/05/14	1372	Metro	House tap at 1-8-59 at Rajendranagar	1.0	Nil	Satisfactory
59	08/05/14	1374	Metro	PSP outside at Miralam Filter Beds	2.0	Nil	Satisfactory
60	08/05/14	1376	Metro	PSP at 19-2-28/A/B /A at Jahanuma Reservoir	2.0	Nil	Satisfactory
61	08/05/14	1377	Metro	PSP at 19-2-43/1 at Jahanuma road	2.0	Nil	Satisfactory
62	08/05/14	1378	Metro	PSP Outside at Aliabad Reservoir	2.0	Nil	Satisfactory
63	08/05/14	1380	Metro	PSP beside at 13-3-10/5 Mustaidpura Kaman road , Sabjimandi Karwan	1.0	Nil	Satisfactory
64	08/05/14	1382	Metro	Outlet tap water in pump room at Karwan S/R	1.5	Nil	Satisfactory
65	08/05/14	1383	Metro	House tap pit at 13-4-655 Pancha Bai Mekalamandi , Iivaonda	1.5	Nil	Satisfactory
66	08/05/14	1385	Metro	PSP opp 13-3-1110/10 Sabjimandi road Karwan	1.5	Nil	Satisfactory
67	08/05/14	1387	Metro	House tap pit 22-6-849/3, Pakeeza bowli Charkaman, Charminar	0.2	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
68	09/05/14	1389	Metro	Pump room tap at Hussainnagar	2.0	23	Unsatisfactory	5/7/2014	2007	1	Nil	Satisfactory
69	09/05/14	1390	Metro	Tap inside at Maredpally Reservoir	1.0	Nil	Satisfactory
70	09/05/14	1392	Metro	Pump room tap at Addagutta Section	2.0	Nil	Satisfactory
71	09/05/14	1394	Metro	PSP at H.No: 1-9-1113/27/186 at Nagamaiah kunta	1.0	Nil	Satisfactory
72	09/05/14	1396	Metro	Pump room tap at Narayanguda Reservoir	2.0	Nil	Satisfactory
73	09/05/14	1398	Metro	Tap in pump room at Hussain sagar pump house	1.0	Nil	Satisfactory
74	09/05/14	1400	Metro	PSP at 1-2-155 Kalariguda , Sec-bad	1.0	Nil	Satisfactory
75	09/05/14	1402	Metro	Tap in pump room at L/L Maredpally S/R	1.0	Nil	Satisfactory
76	09/05/14	1403	Metro	Tanker Filling Point No: I Addagutta Section	1.0	Nil	Satisfactory
77	09/05/14	1405	Metro	PSP Ouside at Tarnaka Section Reservoir	1.0	Nil	Satisfactory
78	09/05/14	1407	Metro	House Tap at 12-13-1187/1, Tarnaka Street No: 10	1.0	Nil	Satisfactory
79	09/05/14	1408	Metro	PSP inside at old Malakpet Section Reservoir	0.5	23	Nil	Unsatisfactory	10/7/2014	2056	1.5	Nil	Satisfactory
80	09/05/14	1410	Metro	PSP opp 16-9-690 Noor Masjid Colony, Old Malaknet	0.5	23	Nil	Unsatisfactory	10/7/2014	2058	1.5	Nil	Satisfactory
81	09/05/14	1411	Metro	PSP Outside Madannapet section Reservoir	0.2	≥1609	Nil	Unsatisfactory	21-6-14	1890	1	Nil	Satisfactory
82	09/05/14	1413	Metro	House Tap at 17-2-569/1 ,Bharat Nagar colony Madannapet	Nil	≥1609	Nil	Unsatisfactory	To be Resampled (During visit no supply)					

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
83	12/05/14	1414	Metro	Tanker Filling Point at Asifnagar Filter Beds	1.5	Nil	Satisfactory
84	12/05/14	1415	Metro	PSP beside 13-6-460/112/1 Gudimalkapur X road Mehdipatnam	1.5	Nil	Satisfactory
85	12/05/14	1417	Metro	PSP beside 13-1-934 Post office lane Manghalhat	1.0	Nil	Satisfactory
86	12/05/14	1419	Metro	PSP beside 14-1-523/A, Ghode Ki Kaber Beerban main road	1.5	Nil	Satisfactory
87	12/05/14	1420	Metro	PSP outside at Bogullakunta Section Reservoir	Nil	93	Nil	Unsatisfactory	7/6/2014	1738	2	Nil	Satisfactory
88	12/05/14	1421	Metro	House tap at 16-9-750/5 Ajantha Colony Old Malakpet	1.0	23	Nil	Unsatisfactory	9/6/2014	1746	1	Nil	Satisfactory
89	12/05/14	1422	Metro	PSP Outlet at Balapur S/R	1.0	23	Nil	Unsatisfactory	9/6/2014	1747	1	Nil	Satisfactory
90	12/05/14	1424	Metro	House tap at 18-1-713/27/A Naseeb Nagar slum Phool Bagh	1.0	Nil	Satisfactory
91	12/05/14	1426	Metro	House tap at 18-1-241/141 Moinbagh slum	1.0	Nil	Satisfactory
92	12/05/14	1428	Metro	PSP at Santoshnagar section reservoir	1.0	Nil	Satisfactory
93	13/05/14	1429	Metro	PSP at plot no: 52, Gun Bazar Contonment	0.5	Nil	Satisfactory
94	13/05/14	1431	Metro	PSP inside at Balam rai section	2.0	Nil	Satisfactory
95	13/05/14	1433	Metro	Tap inside Gun rock section	0.2	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
111	14/5/14	1459	Metro	PSP Inside at Vasavinagar S/R	0.5	Nil	Satisfactory
112	14/5/14	1461	Metro	Tanker No: AP 36W 3089 (Huda complex Saroor Nagar S/R	1.5	Nil	Satisfactory
113	14/5/14	1462	Metro	House Tap at Plot No: 131 Mohannagar Kothapet	1.5	Nil	Satisfactory
114	14/5/14	1464	Metro	House tap at 1-40 Mohannagar Kothapet	1.0	Nil	Satisfactory
115	15/5/14	1465	Metro	House tap pit 3-5-1115/12 Shamsheergunj, Narayanguda	Nil	23	Nil	Unsatisfactory	20-6-14	1862	1	Nil	Satisfactory
116	15/5/14	1467	Metro	House tap pit 3-5-82/24, Rajmohalla Narayanaguda	Nil	1100	Nil	Unsatisfactory	20-6-14	1863	1	43	Unsatisfactory
117	15/5/14	1468	Metro	House tap pit at 1-1-286/8 Street No; 3 Bapunagar Chikkedpally	1.5	Nil	Satisfactory
118	15/5/14	1469	Metro	PSP near 1-8-607/76, Acaiahnagar Baghlingampally	0.5	23	Nil	Unsatisfactory	20-6-14	1864	1.5	Nil	Satisfactory
119	15/5/14	1470	Metro	PSP opp GHMC No; 633 Nagamaiahkunta Vidyanagar	Nil	≥1609	Nil	Unsatisfactory	20-06-14	1866	1.5	Nil	Satisfactory
120	15/5/14	1472	Metro	PSP Outside at Tarnaka S/R	> 2.0	Nil	Satisfactory
121	15/5/14	1473	Metro	House tap pit 12-1-1119/26/A Indira Nagar North Lalaguda Sec-bad	Nil	≥1609	Nil	Unsatisfactory	20-6-14	1868	1	Nil	Satisfactory
122	15/5/14	1475	Metro	Outlet tap at Prashasannagar S/R	1.0	Nil	Satisfactory
123	15/5/14	1477	Metro	PSP outlet at Chilalguda S/R	1.0	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
124	15/5/14	1479	Metro	Outlet tap at Vaishalinagar Section Reservoir	1.0	Nil	Satisfactory
125	15/5/14	1481	Metro	Inside tap at NTR Nagar S/R	1.0	Nil	Satisfactory
126	16/5/14	1482	Metro	Tap inside at Rajendranagar Section	2.0	Nil	Satisfactory
127	16/5/14	1484	Metro	Tap inside at Misrigunj Reservoir	2.0	Nil	Satisfactory
128	16/5/14	1486	Metro	PSP opp 3-3-467 Chappal Bazar , Koti	1.0	Nil	Satisfactory
129	16/5/14	1488	Metro	House tap pit 1-8-747/11/58 Sanjaynagar (Slum) Lingampally	1.5	Nil	Satisfactory
130	16/5/14	1489	Metro	PSP outside at Gandhinagar S/R Ashoknagar	0.1	1100	Nil	Unsatisfactory	3/6/2014	1684	0.2	43	Unsatisfactory
131	16/5/14	1491	Metro	Outlet tap at H.B Colony Section Phase-II	1.0	Nil	Satisfactory
132	16/5/14	1493	Metro	Outlet tap at Navodayanagar Section	1.0	Nil	Satisfactory
133	16/5/14	1495	Metro	Outlet tap at Balanagar S/R Kukatpally	1.0	Nil	Satisfactory
134	16/5/14	1497	Metro	House tap at 6-10-101 Vinayaknagar Slum , kukatpally	1.0	Nil	Satisfactory
135	16/5/14	1499	Metro	PSP at 6-3-708/A/9 Pochamma Basthi Slum	1.0	Nil	Satisfactory
136	16/5/14	1500	Metro	Outlet tap at at Somajiguda S/R	1.0	Nil	Satisfactory
137	17/5/14	1501	Metro	House tap at D.No: 1-3-183/40/91, New Bakaram	1.0	Nil	Satisfactory
138	17/5/14	1502	Metro	House tap at 1-3-183/40/105/29 at D.S Nagar	1.0	Nil	Satisfactory
139	17/5/14	1504	Metro	Tap inside at Hussain Sagar Pump House	2.0	Nil	Satisfactory
140	17/5/14	1506	Metro	PSP at 6-7-888/60 at Bansilalpet	1.5	Nil	Satisfactory
141	19/5/14	1508	Metro	Outlet tap room at Bhagyanagar S/R,KPHB	Nil	23	Nil	Unsatisfactory	To be Resampled (During visit no supply)					
142	19/5/14	1509	Metro	House tap at H.No: 2-1-21/80 Saicharan Colony slum HMT Hills road , KPHB	0.5	Nil	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
143	19/5/14	1511	Metro	House tap pit at plot No: 426 Shathavahana Nagar , Bhagyanagar KPHB	Nil	23	Nil	Unsatisfactory	To be Resampled (During visit no supply)					
144	19/5/14	1513	Metro	House tap pit LIGH APHB No: 136/3 (near LIGH 157) IV th Phase KPHB	Nil	15	Nil	Unsatisfactory						
145	19/5/14	1515	Metro	Tanker Filling Point at IV th Phase S/R KPHB	Nil	09	Nil	Unsatisfactory						
146	19/5/14	1516	Metro	Tanker Filling Point (outside)Narayanguda S/R	1.5	Nil	Satisfactory
147	19/5/14	1517	Metro	House tap at 16-2-741/D/30, Asmangadh TV Tower	1.0	Nil	Satisfactory
148	19/5/14	1519	Metro	Inside tap at 16-2-741/D/30, Asmangadh TV Tower	1.0	Nil	Satisfactory
149	19/5/14	1520	Metro	Outside tap at Chanchalguda S/R	1.0	Nil	Satisfactory
150	19/5/14	1522	Metro	House tap at 16-3-210 Chanchalguda S/R	1.0	Nil	Satisfactory
151	19/5/14	1523	Metro	House tap at Madannapet S/R	1.0	Nil	Satisfactory
152	20/5/14	1524	Metro	PSP outlet at Gouse Nagar, Bandlaguda	0.2	Nil	Satisfactory
153	20/5/14	1520	Metro	PSP Outside at Aliabad Reservoir	2.0	Nil	Satisfactory
154	20/5/14	1528	Metro	PSP at 19-2-21/22/2, Nawab Sahab Kunta	1.0	Nil	Satisfactory
155	20/5/14	1529	Metro	Tanker Filling Point at Misrigunj	2.0	Nil	Satisfactory
156	20/5/14	1530	Metro	PSP at 20-2-531/1 at Hussaini Alam	2.0	Nil	Satisfactory
157	20/5/14	1532	Metro	Tanker Filling Point at Boggulakunta Section Reservoir	1.5	Nil	Satisfactory
158	20/5/14	1533	Metro	House Tap pit inside 15-7-212 Chatri , Bagum Bazar	Nil	93	Nil	Unsatisfactory	To be Resampled (During visit no supply)					
159	20/5/14	1535	Metro	PSP opp 14-7-171, Chudi Bazar , Jummerath Bazar road	Nil	460	Nil	Unsatisfactory						

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
160	20/5/14	1536	Metro	House Tap pit near 14-3-284 Joshiwadi Begum Bazar	1.5	Nil	Satisfactory
161	20/5/14	1537	Metro	PSP outside Gowliguda S/R Afzalgunj	0.1	Nil	Satisfactory
162	20/5/14	1539	Metro	PSP at 9-4-61/17 Meharaj Colony Slum	1.0	Nil	Satisfactory
163	20/5/14	1541	Metro	PSP outlet at Shaikpet S/R, H/L	1.0	Nil	Satisfactory
164	20/5/14	1543	Metro	Tap in pump room at Shaikpet S/R	1.0	Nil	Satisfactory
165	20/5/14	1545	Metro	House tap at 9-4-195, Toli Chowki slum	1.0	Nil	Satisfactory
166	20/5/14	1547	Metro	Inside tap at Asif Nagar S/R	1.0	Nil	Satisfactory
167	20/5/14	1548	Metro	PSP at 10-4-41/1/3 Pochamma Basti Slum	1.0	Nil	Satisfactory
168	20/5/14	1549	Metro	House tap pit 3-5-948/59 Gandhi Kuter (Slum)Narayanguda	1.5	09	Nil	Unsatisfactory	19-06-14	1850	1	Nil	Satisfactory
169	20/5/14	1551	Metro	PSP near 1-8-855/7 Ram Nagar Bagh Lingampally	1.5	Nil	Satisfactory
170	20/5/14	1552	Metro	PSP opp 2-2-1107/15/B Bhavani Temple Lane Rly Building, Nallakunta	1.0	Nil	Satisfactory
171	22/5/14	1554	Metro	House tap pit Street No; 2 GHMC -170 Vidyanagar Narsimha basti	1.0	Nil	Satisfactory
172	22/5/14	1556	Metro	House tap pit 2-3-42/C/51A Quadribagh (near) 2-3-42/C/49 Amberpet	1.0	Nil	Satisfactory
173	22/5/14	1557	Metro	PSP outlet tap at Azampura S/R	1.0	09	Nil	Unsatisfactory	To be Resampled (During visit no supply)					
174	22/5/14	1559	Metro	House tap at 16-7-18 Azampura Colony Slum	1.0	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
175	22/5/14	1560	Metro	House tap 16-3-472/6 Chanchalguda colony	1.0	93	Unsatisfactory	To be Resampled (During visit no supply)					
176	22/5/14	1561	Metro	House tap at 16-3-472/A Chanchalguda colony	1.0	07	Unsatisfactory						
177	22/5/14	1563	Metro	PSP outlet at Santosh Nagar S/R	1.0	Nil	Satisfactory
178	22/5/14	1565	Metro	House tap at 17-1-182/4, Banu Nagar Slum, Santoshnagar	1.0	0.7	Unsatisfactory	To be Resampled (During visit no supply)					
179	22/5/14	1566	Metro	Tap inside at Erragadda Reservoir	2.0	Nil	Satisfactory
180	22/5/14	1568	Metro	PSP Outlet at Borabanda Section	2.0	Nil	Satisfactory
181	22/5/14	1570	Metro	Tap inside at S.R Nagar Section	2.0	Nil	Satisfactory
182	22/5/14	1572	Metro	PSP Outlet at LIC Colony , Domalguda S/R	0.5	Nil	Satisfactory
183	22/5/14	1574	Metro	PSP near 6-4-26/B Musheerabad X road	1.5	Nil	Satisfactory
184	22/5/14	1575	Metro	PSP near Govt Primary School ,Krishnanagar ,Bholakpur	1.5	Nil	Satisfactory
185	22/5/14	1577	Metro	House tap beside 1-4-26 Ranganagar Bholakpur	1.5	Nil	Satisfactory
186	22/5/14	1578	Metro	House tap at 12-2-37/B/90, Zebanagar slum Asif Nagar	1.0	Nil	Satisfactory
187	22/5/14	1580	Metro	PSP at 12-2-36/1/A/B Asifnagar , Muradnagar slum	1.0	Nil	Satisfactory
188	24/5/14	1581	Metro	PSP at 12-1-575/B/10 Murad Nagar slum	1.0	Nil	Satisfactory
189	24/5/14	1583	Metro	PSP at 12-2-683/A/2 Gudimalakapur slum	1.0	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
190	24/5/14	1585	Metro	PSP at 12-2-708/2/19 Bojagutta , Vivekananda Nagar	1.0	Nil	Satisfactory
191	24/5/14	1586	Metro	PSP 6-3-311 at Bodapuram	1.0	Nil	Satisfactory
192	24/5/14	1588	Metro	Tanker Filling at Banjara Hills section	1.5	Nil	Satisfactory
193	24/5/14	1590	Metro	Tap inside Thatti Khana section	1.5	Nil	Satisfactory
194	24/5/14	1592	Metro	Tap inside at Yellareddyguda sectin	2.0	Nil	Satisfactory
195	24/5/14	1593	Metro	PSP near 11-2-1082 Bazar ghat X road Nampally	0.5	Nil	Satisfactory
196	24/5/14	1594	Metro	House tap pit 11-3-229 Zafershah Ki road Beaghanagar (Nala) Mallepally	0.5	Nil	Satisfactory
197	24/5/14	1596	Metro	PSP opp 12-1-64 beside Gas Company Lane old Mallapally	Nil	150	Nil	Unsatisfactory	To be Resampled (During visit no supply)					
198	24/5/14	1598	Metro	House tap pit 12-1-331/155/A, Old Mallapally Asif Nagar	Nil	210	Nil	Unsatisfactory						
199	24/5/14	1599	Metro	PSP beside 12-2-666 old Mandudeguda (Slum) Gudimalkapur	1.0	Nil	Satisfactory
200	24/5/14	1600	Metro	Outlet tap at Maisaram S/R Barkas, Salala	1.0	Nil	Satisfactory
201	24/5/14	1602	Metro	House tap at 18-8-123/A/C Mainbagh slum, Balapur	1.0	Nil	Satisfactory
202	24/5/14	1603	Metro	House tap at 18-8-241/119 Edi Bazar, Moin Bagh	1.0	Nil	Satisfactory
203	24/5/14	1605	Metro	House tap at 18-8-537/3, Edi Bazar slum,Kumariwada	1.0	Nil	Satisfactory
204	27/5/14	1606	Metro	House tap at 18-8-524 Kumarwada slum	1.0	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
205	27/5/14	1607	Metro	Tap inside Tarnaka Reservoir	2.0	Nil	Satisfactory
206	27/5/14	1609	Metro	House tap at 12-13-1096 at Chintal Tarnaka	1.5	Nil	Satisfactory
207	27/5/14	1610	Metro	House tap at 1-6-27/67 at Gandhi Girijan Colony,	0.2	Nil	Satisfactory
208	27/5/14	1612	Metro	PSP inside at Beerappagadda Section	0.5	Nil	Satisfactory
209	27/5/14	1614	Metro	House tap 2-20/5/5/1 Adarshnagar Chullakguda, Uppal	2.0	Nil	Satisfactory
210	27/5/14	1615	Metro	House tap 2-20-9/21, Chullakguda, Uppal	0.2	Nil	Satisfactory
211	27/5/14	1617	Metro	House tap MCH Quarters, Gandhi Statue,Amberpet	2.0	Nil	Satisfactory
212	27/5/14	1619	Metro	PSP outside at Gandhi Nagar S/R Ashoknagar, Musheerabad	1.0	Nil	Satisfactory
213	27/5/14	1620	Metro	House tap pit 1-1-652/K/30 Arundhathi Nagar slum Gandhinagar	1.5	Nil	Satisfactory
214	27/5/14	1621	Metro	PSP opp 1-1-650 Anna Nagar Slum , Gandhi Nagar, Ashoknagar	1.0	Nil	Satisfactory
215	27/5/14	1622	Metro	House tap 1-9-1113/27/F/193/C/1 Nagamaiah Kunta , Vidyannagar	Nil	04	Nil	Unsatisfactory	20-6-14	1866	1.5	Nil	Satisfactory
216	28/5/14	1624	Metro	Outlet tap at Kailasagiri Section Reservoir, Kapra	Nil	43	Nil	Unsatisfactory	To be Resampled (During visit no supply)					
217	28/5/14	1626	Metro	Outlet tap at H.B Colony Section Phase-II	Nil	23	Nil	Unsatisfactory						
218	28/5/14	1628	Metro	PSP Outlet at Moula Ali section , Malkajgiri	1.0	Nil	Satisfactory
219	28/5/14	1630	Metro	Outlet tap at Chanakyapuri section , Malkajgiri	1.0	Nil	Satisfactory
220	28/5/14	1632	Metro	House tap at 45-100/12 N.M.D.C Colony ,Malkajgiri	1.0	Nil	Satisfactory
221	28/5/14	1633	Metro	House tap at 12-14-451 , Isuka Basti slum, Lalapet	1.0	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
222	28/5/14	1634	Metro	Tanker Filling Point at S.R Nagar Section	1.5	Nil	Satisfactory
223	28/5/14	1636	Metro	House tap at D.No : 8-3-320/1/42 Ambedkar Nagar Ameerpet	1.0	Nil	Satisfactory
224	28/5/14	1638	Metro	Tap inside at Yellareddyguda Section	2.0	Nil	Satisfactory
225	28/5/14	1640	Metro	House tap at Plot No : 48 at Kamalapuri Colony Srinagar colony	1.5	Nil	Satisfactory
226	29/5/14	1641	Metro	House tap pit at 6-4-260 Telephone exchange lane , Bholakpur	0.5	Nil	Satisfactory
227	29/5/14	1642	Metro	PSP opp 1-4-60/4 Ranganagar, Bholakpur	0.5	Nil	Satisfactory
228	29/5/14	1644	Metro	Outlet tap (Comp-II) Boiguda S/R, Mekalamandi	0.5	Nil	Satisfactory
229	29/5/14	1646	Metro	Tanker Filling Point at (Remoulding S/R) Chilkalguda S/R	Nil	Nil	Satisfactory
230	29/5/14	1647	Metro	Tanker Filling Point at Red Hills Section	2.0	Nil	Satisfactory
231	29/5/14	1649	Metro	House tap at H.No; 4-1-2224 at Hanuman Tekdi , Abids	1.5	Nil	Satisfactory
232	29/5/14	1650	Metro	PSP at H.No: 4-4-932/1 at Royal Takies road Sultan Bazar	1.5	Nil	Satisfactory
233	30/5/14	1652	Metro	Pump room at Prashanthnagar Section	2.0	Nil	Satisfactory
234	30/5/14	1654	Metro	Tap inside at white tank , Vanasthalipuram	0.5	Nil	Satisfactory
235	30/5/14	1655	Metro	House tap at B-631 at N.G.O's Colony, Vanasthalipuram	0.2	Nil	Satisfactory
236	30/5/14	1657	Metro	Tap inside at Green Tank, Vanasthalipuram	0.5	Nil	Satisfactory

Sl. No.	Date of Collection	Lab Ref No.	Source	Exact Location	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	MPN of E.coli	Remarks	Resampling result of unsatisfactory points					
										Date of Collection	Lab Ref No.	Residual Chlorine mg/l	MPN index of coliform Bacteria per 100 ml	Nature of coliform Bacteria isolated	Remarks
237	30/5/14	1659	Metro	PSP Outside at Vyshnavi Colony section	1.5	Nil	Satisfactory
238	30/5/14	1661	Metro	PSP outside at Santoshnagar section	2.0	23	Nil	Unsatisfactory	15-7-14	2097	2	Nil	Satisfactory
239	30/5/14	1663	Metro	PSP outside at Yakatpura Booster	1.5	Nil	Satisfactory
240	30/5/14	1664	Metro	Hous etap at 16-11-16/14/B/2 Teegalguda	Nil	23	Nil	Unsatisfactory	To be Resampled (During visit no supply)					
241	30/5/14	1665	Metro	Tanker Filling Point (Outside) Narayanguda S/R	0.2	Nil	Satisfactory
242	31/5/14	1666	Metro	PSP at H.No; 18-4-613 Aliabad, Shamsheergunj	1.0	Nil	Satisfactory
243	31/5/14	1668	Metro	PSP outlet at Aliabad Section Reservoir	1.0	Nil	Satisfactory
244	31/5/14	1670	Metro	PSP at Moghalpura Section Reservoir	1.0	Nil	Satisfactory
245	31/5/14	1672	Metro	PSP at 20-7-619 Shahgunj	1.0	Nil	Satisfactory
246	31/5/14	1673	Metro	PSP at 15-2-32 Gowliguda Chaman	1.0	23	Nil	Unsatisfactory	To be Resampled (During visit no supply)					

Abstract (first sampling)		Result of Resampling of unsatisfactory samples	BACTERIOLOGICAL STANDARDS OF DRINKING WATER	
Total No. of samples tested for Residual Chlorine in water samples	2026	• Untreated water	Faecal coliforms should be Zero (0) Coliform organism in any one sample should not be more than 10 per 100ml,
Total No. of samples found Residual Chlorine satisfactory	2001		
Total No. of samples found Residual Chlorine Nil	25	• Treated water	Faecal coliforms should be Zero (0) Coliform organism in any one sample should not be more than 4 per 100ml,
Total No. of Samples Collected and tested for Bacteriological quality	246	43		
No. of Samples Bacteriologically found satisfactory	203	3	• Un piped Supplies	Coliform organisms should not be more than 10 per 100 ml, Faecal coliforms should be Zero (0)
No. of Samples Bacteriologically found unsatisfactory	43	25		
Testing under process		• Emergency supplies	Coliform Organismsshould not be more than 10 per 100 ml, Faecal coliforms should be Zero (0) No Sample should contain E.coli in 100ml.
To be resampled		18((During visit no supply)		

